



Sertifikat Certificate



**INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU**
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs

SERTIFIKAT

☒ O PREGLEDU TIPA/ Type examination

Broj / Number: T 2224

☐ POJEDINAČNI PREGLED/Single examination

Strana / Page: 1 / 2

Na zahtev naručioca / By the request of purchaser: **FERROLI, S.p.A., Via Ritonda 78/a, 37047 San Bonifacio, Italija / Italy**

preduzeto je/ has been undertaken: **Kontrolisanje novog proizvoda the new product inspection**

u vezi sa Izveštajem o usaglašenosti/ in relation to Inspection report:

Broj / Number: T 2224

sa dokumentima u prilogu/ with attached documents:

- Uputstvo za korišćenje / User's manual
- Uputstvo za instaliranje / Installation instruction;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaji o ispitivanju IMP CGT T 1942, T 1943 / Test reports IMP CGT T 1942, T 1943

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja / subject of the inspection: **GASNI KOTAO / GAS BOILER**

proizveden od / manufactured by: **FERROLI, S.p.A., Via Ritonda 78/a, 37047 San Bonifacio, Italija / Italy**

oznaka - tip - serija / mark - type - series: **DIVA D...**

vrsta/type: **B₂₂, C₁₂, C₃₂**
kategorija/category: **II_{2H3B/P}**

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u / as specified in the Annex A, meets the requirements listed in:

Pravilnik o zahtevima za projektovanje, izradu i ocenjivanje usaglašenosti gasnih aparata ("Sl. gl. RS", br. 41/2015)

SRPS EN 15502-2-1:2013

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /

The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012 and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.

Ocenjivanje sprovedeno / Evaluation performed from 18.10.2022. ÷ 09.12.2022.

izdat od / issued by:

**INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE**
Kristina Petković dipl.maš.inž.

mesto, datum / place, date: **M.P. / S.P.
Beograd, 09.12.2022.**



Ime, Prezime / Name, Surname



Sertifikat Certificate



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs

Prilog A / Annex A

oznaka - tip - serija / DIVA D...
mark - type - series :

Broj / Number: T 2224

Strana / Page: 2 / 2

vrsta/type: B₂₂, C₁₂, C₃₂
kategorija/category: II_{2H3B/P}

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
DIVA D ...		
...F24	Q _n = 8,3 ÷ 25,8 kW P _n = 7,2 ÷ 24,0 kW PMS=3 bar, PMW=9 bar	za grejanje i pripremu tople sanitarne vode (TSV) / for heating and preparation of domestic hot water (DHW)
...F32	Q _n = 11,5 ÷ 34,4 kW P _n = 9,9 ÷ 32,0 kW Tmax=90°C IPX4D	
...F37	Q _n = 14,0 ÷ 39,7 kW P _n = 12,9 ÷ 37,0 kW NOx 3 230V, 50 Hz	

Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. /
Any changes on the device must be reported to the issuer of this document.

Definisani rok narednog pregleda je godinu dana u sklopu ocenjivanja
Deklaracija usaglašenosti sa tipom! / The deadline for the next review is one
year within the assessment of the Declaration of Conformity with the type!